

Comparison of GA and PS Optimization Mechanisms for Optimizing 100MW Delta IV Ughelli Gas Turbine Power Plant Operating Parameters

Ugwuoke Philip Emeka

Department of Mechanical Engineering, Petroleum Training Institute, Effurun, Nigeria.

Abstract

A comparative analysis for improving the efficiency of 100MW Delta IV Ughelli gas turbine power plant is performed. The study used non-dominated sorting genetic and pattern search algorithms to minimize the objective function by optimally adjusting the operating parameters (decision variables). The adjusted operating variables were compressor inlet temperature (T_1), compressor pressure ratio (r_p), compressor isentropic efficiency (η_c), turbine isentropic efficiency (η_t), turbine exhaust temperature (T_4) and mass flow rate (m_a), fuel mass flow rate (m_f) and fuel supply temperature (T_f). The ambient temperature and pressure were held constant at 304K and 1.01325bar respectively because of location limitation. The optimization code was written in Matlab programming language. The decision variables (constraints) were obtained randomly within the admission range. The GA and PS optimal values of the decision variables were obtained by minimizing the objective function. The determined GA and PS optimum operating variables have the same values which were $r_p = 9.76$, $\eta_c = 86.40\%$, $\eta_t = 89.12\%$, $T_3 = 1481.8K$, $m_a = 530kg/s$, $m_f = 7.00kg/s$. The total exergy destruction cost rate (C_o) for PS and GA varies by +0.00004% and the total investment cost rate Z_k for PS and GA varies by +0.00038%. The results show that there is slight increase in total exergy destruction cost rate and total capital investment cost rate Z_k in PS optimum when compared to GA optimum. This shows that GA is better than PS as an optimization algorithm.

Keywords: Comparative Analysis, Optimizing, Genetic Algorithm, Pattern Search

Introduction

The most effective means for improving the performance of existing power plants in order to attain high thermal efficiency, reliability and low operating cost has continued to agitate the minds of Engineers. This research uses exergy analysis, a method that uses the conservation of mass and conservation of energy principles together with the second law of thermodynamics for the design and analysis of thermal systems.^[1] Genetic Algorithm and pattern search were used to minimize the exergy destruction by optimally adjusting the operating parameters. Genetic Algorithm as an optimization tool works based on Charles Darwins theory of evolution (survival of the fittest). Genetic algorithm was

originally designed as simulator but has proven to be a robust optimization technique.^[2-3] Genetic algorithm uses two operators to generate new solutions from existing ones: crossover and mutation. The crossover operator is the most important operator of GA. In crossover, two chromosomes called parents are combined to form new chromosomes, called off-springs. The parents are selected among the existing chromosomes in the population with preference to fitness. This enables the off-springs to inherit good genes making them better than their parents. By iteratively applying the crossover operator, genes of good chromosomes are expected to appear more frequently in the population, eventually leading to convergence

E-mail Id: ugwuokeemeka@gmail.com

Orcid Id: <https://orcid.org/0000-0003-2721-2516>

How to cite this article: Emeka UP. Comparison of GA and PS Optimization Mechanisms for Optimizing 100MW Delta IV Ughelli Gas Turbine Power Plant Operating Parameters. *J Adv Res Power Electro Power Sys* 2018; 5(3&4): 1-7.

Copyright (c) 2018 Journal of Advanced Research in Power Electronics & Power Systems (ISSN: 2456-1401)



to an overall good solution. The mutation operator introduces random changes into the characteristics of the chromosomes. The aim of mutation is to introduce new genetic material into existing individual; that is, to add diversity to the genetic characteristics of the population. The population which is created randomly at the onset is called initial population. The size of this population may vary from several tens of chromosomes (strings) to several thousands. The criterion applied in determining an upper bound for the size of population is that further increase does not result in improvement of near-optimal solution. The upper bound for each problem is determined after some test runs. For most applications, the best population size lies within the limits of 100 – 1000 strings.^[2-3] On the basis of the optimality (measure of goodness) value, an objective function value or fitness value is assigned to each string. This fitness usually set as the amount of optimality of each string in the population divided by the average population optimality. Effort is always made to ensure that the fitness value is a positive number.^[2] It is possible that a certain string does not reflect an allowable condition. For such a case, the fitness of the string is penalized with a very low value, indicting in such a way to the GA that it is not a good string. Similarly, other constraints may be implemented in the GA. The “operators”, which are kinds of population transformation devises, are applied to the population. As a result of these operators, a new population is created, that will hopefully consist most optimal strings. The old population is replaced by new one. A predefined stopping criterion, usually maximum number of generation s to be performed by the GA is checked. If the criterion is not satisfied, a new generation is started, otherwise, the GA terminates.

Pattern search(PS), algorithm proceeds by computing a sequence of points that may or may not approach to the optimal point. The algorithm starts by establishing a set of points called mesh, around the given point. This current point could be the initial starting point supplied by the user or it could be computed from the previous step of the algorithm. The mesh is formed by adding the current point to a scalar multiple of a set of vectors called a pattern. If a point in the mesh is found to improve the objective function at the current point, the new point becomes the current point at the next iteration.

This maybe better explained by the following^[4]:

First, the pattern search begins at the initial point X_0 that is given as a starting point by the user. At the first iteration, with a scalar = 1 called mesh size, the pattern vectors are constructed as $[0\ 1]$, $[1\ 0]$, $[1\ 0]$, and $[0\ 1]$, they may be called direction vectors. Then the pattern search algorithm adds the direction vectors to the initial point X_0 to compute the following mesh points:

$$X_0 + [1\ 0]$$

$$X_0 + [0\ 1]$$

$$X_0 + [-1\ 0]$$

$$X_0 + [0\ -1]$$

The algorithm polls the mesh points by computing their objective function values until it finds one whose value is smaller than the objective function value of X_0 . If there is such point, then the poll is successful and the algorithm sets this point equal to X_1 .

After a successful poll, the algorithm steps to iteration 2 and multiplies the current mesh size by 2, (this is called the expansion factor and has a default value of 2). The mesh at iteration 2 contains the following points: $2^*[10]+X_1$, $2^*[01]+X_1$, $2^*[-10]+X_1$ and $2^*[0-1]+X_1$. The algorithm polls the mesh points until it finds one whose value is smaller than the objective function value X_1 . The first such point it finds is called X_2 . And the poll is successful. Because the poll is successful, the algorithm multiplies the current mesh size by 2 to get a mesh size of 4 at the third iteration because the expansion factor = 2.

Secondly, if iteration 3, (mesh size = 4), ends up being unsuccessful poll, i.e. none of the mesh points has a smaller objective function value than the value at X_2 , so the poll is called an unsuccessful poll. In this case, the algorithm does not change the current point at the next iteration. That is, $X_3 = X_2$. At the next iteration, the algorithm multiplies the current mesh size by 0.5, a contraction factor, so that the mesh size at the next iteration is smaller. The algorithm then polls with a smaller mesh size.

The pattern search optimization algorithm will repeat the illustrated steps until it finds the optimal solution for the minimization of the objective function. The algorithm stops when any of the following conditions occurs:

- The mesh size is less than mesh tolerance.
- The number of iterations performed by the algorithm reaches a predefined value.
- The total number of objective function evaluations performed by the algorithm reaches a pre-set maximum number of function evaluations.
- The distance between the point found at one successful poll and the point found at the next successful poll is less than a set tolerance.
- The change in the objective function from one successful poll to the next successful poll is less than a function tolerance.

The objective is to carry out a comparative Analysis for optimal performance of 100MW Gas Turbine Power Plant using GA and PS algorithms to minimize the exergy destruction cost rate by optimally adjusting the operating parameters. The parameters are: compressor pressure ratio, compressor isentropic efficiency, turbine isentropic

efficiency, fuel mass flow rate, and air mass flow rate and turbine inlet temperature.

Materials and Method

The data used for this analysis are real time values recorded in the station's operational log book for the period of January 2005 – December 2014[5] for 100MW Delta IV gas turbine at various state points. These recorded values of the parameters were taken in the station every one hour interval for twenty four hours (i.e. daily). Then, the daily, monthly and yearly average values of the parameters were calculated using the EXCEL statistical tool. This exercise is carried out for ten consecutive years. The analysis was carried out with GA tool box in Matlab (Version 2011b). Figure 1 shows the schematic diagram of the power plant demonstrating all its relevant components. In analysis of the plant, the operating parameters of the plant^[6] as shown in table 1 below and exergoeconomic principles were used.




Figure 1. Schematic diagram of the plant

Table 1. Operating Parameters of Delta power plant

Property	Value
Ambient Temperature, T_1	303K
Compressor outlet temperature, T_2	632.2K
Temperature of the fuel T_f	298.15K
Turbine inlet temperature, T_3	1238.5K
Turbine outlet temperature, T_4	807K
Compressor inlet pressure, P_1	1.013bar
Compressor outlet pressure, P_2	10.6 bar
Compressor pressure ratio, r_p i.e. $\frac{P_2}{P_1}$	10.47
Compressor isentropic efficiency, η_c	88%
Turbine isentropic efficiency, η_t	89%
Mass flow rate of fuel, \dot{m}_f	7.04 kg/s
Inlet mass flow rate of air, \dot{m}_a	427kg/s
power output, W_{net}	46.91(MW)
Lower heating value of fuel, Q	50kJ/kg

Exergoeconomic Principles

The capital investment cost rates for the components were determined based on the modeling expression recommended by.^[7] Using the capital recovery factor (CRF(i,n)) and present worth factor (PWF(i,n)), the annual leveled cost may be written as:

$$\dot{C} = PEC - (SV)PWF(i, n)CRF(i, n) \quad (1)$$

Where $SV = 0.1PEC$, $CRF(i, n) = i/[1 - (1 + i)^{-n}]$,
 $PWF(i, n) = (1 + i)^{-n}$,

And PEC is the purchased-equipment cost. Equations for calculating the purchased-equipment costs for the components of the gas turbine power plant [10] are:

For the Compressor, it is expressed as

$$PEC_{ac} = \left(\frac{71.1m_a}{0.9 - \eta_{ic}}\right) \left(\frac{P_2}{P_1}\right) \ln\left(\frac{P_2}{P_1}\right) \quad (2)$$

For the Combustion Chamber, it is expressed as

$$PEC_{cc} = \left[\frac{46.08m_a}{0.995 - \frac{P_3}{P_2}}\right] [1 + \exp(0.018T_3 - 26.4)] \quad (3)$$

For the Turbine, it is given as

$$PEC_{gt} = \left(\frac{479.34m_g}{0.92 - \eta_{it}}\right) \ln\left(\frac{P_3}{P_4}\right) [1 + \exp(0.036T_3 - 54.4)] \quad (4)$$

Dividing the leveled cost by 8000 annual operating hours (about one month in a year the power plant will be off for maintenance) [8], it is obtained that the capital cost rate for the k^{th} component of the plant:

$$\dot{Z}_k = \left(\frac{\phi_k \dot{C}_k}{8000}\right) \quad (5)$$

The maintenance cost is taken into consideration through the factor $\phi_k = 1.06$ for each plant component whose expected life is assumed to be 15 years and the interest rates is 14%.^[9] The number of hours of plant operating per year and the maintenance factor utilized in this study are the typical numbers employed in standard exergoeconomic analysis.^[10]

The formulations of cost balance for each component and the required auxiliary equations are:

For the compressor, it is expressed as

$$\dot{C}_2 = \dot{C}_1 + \dot{C}_{Wc} + \dot{Z}_c \quad (6)$$

where the subscripts w_c denotes the power input to the compressor.

For the Combustion Chamber, it is expressed as

$$\dot{C}_3 = \dot{C}_2 + \dot{C}_f + \dot{Z}_{cc} \quad (7)$$

For the Turbine, it is given as

$$\dot{C}_4 + \dot{C}_{Wc} + \dot{C}_{Wt} = \dot{C}_3 + \dot{Z}_t \quad (8)$$

$$\frac{\dot{C}_3}{\dot{E}_3} = \frac{\dot{C}_{Wt}}{W_t} \quad (9)$$

Where denotes the net power generated by the turbine. Auxiliary equation (9) is written assuming the same unit cost of incoming fuel and outgoing exergy streams. A zero unit cost is assumed for air entering the compressor (i.e. $\dot{C}_1 = 0$). Additional auxiliary equation is formulated assuming the same unit cost of exergy for the net power output of the system and power input to the compressor:

$$\frac{\dot{C}_{Wt}}{W_t} = \frac{\dot{C}_{Wc}}{W_c} \quad (10)$$

The information of the cost streams help in exergoeconomic evaluation of the system. In exergoeconomic evaluation of thermal systems, certain quantities, known as exergoeconomic variables, play an important role. These are the average unit cost of fuel ($c_{f,k}$), average unit cost of product ($c_{p,k}$), the cost rate of exergy destruction ($\dot{C}_{D,k}$), and the exergoeconomic factor (f_k).

Mathematically, these are expressed [11] as:

$$c_{F,k} = \frac{\dot{C}_{F,k}}{\dot{E}_{F,k}} \quad (11)$$

$$c_{P,k} = \frac{\dot{C}_{P,k}}{\dot{E}_{P,k}} \quad (12)$$

$$\dot{C}_{D,K} = c_{F,K} \dot{E}_{D,K} \quad (13)$$

$$f_k = \frac{\dot{Z}_k}{\dot{Z}_k + \dot{C}_{D,k}} \quad (14)$$

Exergy costing balances (exergoeconomic balances) were carried out for each component. The exergy cost balance consists of operating cost rate (fuel cost rate), capital cost rate and product cost rate.

The cost balance equation is given as;

$$\dot{Z}_K + \sum \dot{C}_{F,K} = \sum \dot{C}_{P,K} \quad (15)$$

Economic Constraints

For a component receiving a heat transfer and generating power, cost balance equation may be written as^[12]:

$$\sum_e \dot{C}_{e,K} + \dot{C}_{W,K} = \dot{C}_{Q,K} + \sum_i \dot{C}_{i,K} + \dot{Z}_K \quad (16)$$

where \dot{C} denotes a cost rate associated with an exergy stream and the variable \dot{Z} represents non-exergetic costs.

The Objective Function

The objective function expresses total cost rate of the plant in terms of naira per unit time.

i. e. $OF = \dot{C}_{ptotal} = \dot{C}_f m_f LHV + \sum \dot{Z}_K + \sum \dot{C}_{D,K}$ (17)

The thermal system requires two conflicting objectives;

one being increase in exergetic and energy efficiencies and the other is decrease in product cost to be satisfied simultaneously. The maximization of exergetic efficiency means minimization of exergy destruction cost. Thus, the objective function becomes a minimization problem. The objective function for this problem is defined as to minimize a total cost function which is modelled as:

$$\dot{C}_{ptotal} = \dot{C}_{ftotal} + \sum \dot{Z}_K \quad (18)$$

In this optimization, compressor pressure ratio compressor isentropic efficiency, turbine isentropic efficiency, combustion product temperature, air mass flow rate, fuel mass flow rate, temperature of the fuel are taken as decision variables.

The stopping conditions used for solving the optimization problem are the maximum number of generations/iterations and cumulative function tolerance, which are shown in Table 3.

Table 2. Stop criteria for the optimization algorithms

	No of Generation	No of Iteration	Function Tolerance
GA	300		1×10^{-7}
PS		50	1×10^{-6}

Genetic Algorithm Optimization

The optimization is done using Non-Dominated Sorting Genetic Algorithm (NSGA) proposed by.^[13] The algorithm




Figure 2. Flowchart for GA optimization

Source [6]

eliminates higher computational complexity, lack of elitism and the requirement for specifying sharing parameter. The developed GA code selects the decision variables in such a way to decrease the objective function. The flowchart of the algorithm is shown in Figure 2. The optimization code was written in MATLAB programming language. The optimal values of the decision variables (constraints) were obtained by minimizing the objective function.

Pattern Search Algorithm Optimization

The pattern Search (PS) optimization is done using direct search method. Direct search methods are simply structured to explore a set of points, around the current position, looking for a point that has smaller objective function value than the current one. The objective function computation code was written in MATLAB programming language. Unlike genetic algorithm^[14-15], PS possesses a flexible and well-balanced operator to enhance and adapt the global and fine tune local search. The flow chart of the algorithm is shown in figure 3




Figure 3. Flow chart of pattern search

Source^[4]

Results and Discussion

As shown in table 4, the values of variables v_p , η_{ic} , η_{it} , T_3 , m_a , m_f are the same for GA and PS optimal results but v_p , η_{ic} , η_{it} and T_3 increased when compared to base results. Increase in v_p is by 6.78%, η_{ic} is by 1.8%, η_{it} is by 0.13% while T_3 is by 19.64%. Increased v_p results in higher thermal efficiency for GA and PS results, while increase in η_{ic} guarantees less energy destruction in the compressor [1, 16, 17] as shown in table 3 for both GA and PS results. Also, in table 4, m_f

Table 3. Comparison of the base and optimal Results

Property	Base Data	GA Optimal Results	PS Optimal Results
Compressor Pressure Ratio (r_p)	10.47	9.76	9.76
Compressor Isentropic Efficiency η_{ic} (%)	88.0	86.4	86.4
Turbine Isentropic Efficiency η_{it} (%)	89.00	89.12	89.12
Turbine Inlet Temperature T_3 (K)	1,238.5	1,481.8	1,481.8
Output Power W_t (MW)	188.2	277.11	277.11
Input Power, W_c (MW)	141.29	169.63	169.63
Total Exergy Destruction, E_{DT} (MW)	224.05	67.10	67.10
Total Cost Rate C_T (\$/hr)	24451.99	13292	13292
Fuel Cost Rate C_f (\$/hr)	2914.10	2898	2898
Total Exergy Destruction Cost Rate C_D (\$/hr)	14722.38	2310.18	2310.18
Total investment Cost rate C_k (\$/hr)	6815.44	8083.65	8083.65
Plant Exergy Efficiency, η_e (%)	13	29	29
Plant Energy Efficiency η_e (%)	13	31	31
Mass flow rate Air m_a (kg/s)	427.00	530	530
Mass flow Rate of fuel mf (kg/s)	7.04	7.00	7.00

Table 4. Comparison of Component Data for Base, GA and PS Optimal Results

Components	Exergy Destruction E_D (MW)			Exergy Destruction Cost Rate (\$/hr)			Exergy Efficiency η_e (%)			Capital Investment Cost rate Z_k (\$/hr)		
	Base	GA	PS	Base	GA	PS	Base	GA	PS	Base	GA	PS
Compressor	8.30	11.58	11.58	237.6	288.58	288.59	94.13	93.17	93.17	4,934.4	3,079	3,079
Combustion Chamber	197.11	33.46	33.46	13,722	1,547	1,547	61.18	93.7	93.7	75.54	306.45	306.45
Turbine	18.64	22.06	22.06	746.31	474.6	474.6	90.99	92.63	92.63	1,805.5	4,698.2	4,698.5

and m_a values are the same for both GA and PS optimal results but m_a increases and m_f decreases when compared to base results. The increase in m_a result is by 24.12% and m_f is by -0.57%. Reduced m_f and increase in m_a contribute to the reduction of total exergy destruction for both GA and PS results. Minimization of exergy destruction means maximization of energetic efficiency^[18,7,5] as shown in table 3 for both GA and PS results.

As shown in table 4, the values of total exergy destruction cost rate, (C_D) and total investment cost rate (Z_k) increases slightly in PS results when compared to GA results. These show that GA is better than PS as an optimization tool.

Conclusion

The comparative analysis of the plant optimal operating parameters has been carried out using genetic and pattern search Algorithms. The optimal values as shown in table 3 show that v_p , η_{ic} , η_{it} , T_3 , m_a , m_f for GA and PS algorithms increase from the base values by 6.78%, 1.8%, 0.13%, 19.64%, 24.12%, -0.57% respectively, but are the same for both algorithms. The total exergy destruction C_D and total investment cost rate Z_k for PS optimal results increase slightly when compared to GA optimal results. These show that GA algorithm is a better optimization technique than PS algorithm. Genetic algorithm, however, uses large search space and many generations for optimization whereas pattern search find certain direction and comparatively less steps for solving the problem. Hence, in a machine related complicated problem, GA as an optimizing algorithm is preferable.

References

1. Bejan A, Tsatsaronis G, Moran M. Thermal Design and Optimization. Wiley, New York. 1996
2. Coley AD. An Introduction to Genetic Algorithms for Scientists and Engineers, 2nd Edition, World Scientific Publishing Co. Pte. Ltd, Singapore, 1999: 211.
3. Malhotra R, Singh N, Singh Y. Genetic Algorithms: Concepts, Design for Optimization of Process Controllers, Computer and Information Science 2011; 4(2): 39-54.
4. Al-Sumait JS, Al-Othman AK, Sykulski JK. (). Application of Pattern Search Method to Power System Valve-Point Economic Load Dispatch. *Journal of Electrical Power and Energy Systems* 2007: 720-730.
5. PHCN. Ughelli Power Plant Logbook, Ughelli, Delta State, Nigeria. 2015
6. Obodeh O, Ugwuoke PE. Optimal Operating Parameters Of 100mw Delta Iv Ughelli Gas Turbine Power Plant Unit, in press 2017.
7. Moran MJ, Shapiro H. Fundamentals of Engineering Thermodynamics, 4th Edition, Wiley, New York, 2000
8. Khosravi A, Gorji-Bandpy M, Fazelpour F. Optimization of a Gas Turbine Cycle by Genetic and PSO Algorithms. *Journal of Middle East Applied Science and Technology (JMEAST)* 2014; 21: 706-711.
9. Emefiele G. MPR: Banks Raise Interest Rates on Existing Loans. Punch Newspapers, July 29. 2016
10. Moran MJ. Availability Analysis; A Guide to Efficient Energy Use, USA: Prentice Hall, Englewood Cliffs NJ. 1982.
11. Ebadi M, Gorji-Bandpy M. Exergetic Analysis of Gas Turbine Plants. *International Journal of Exergy* 2005 2(4): 31-39.
12. Gorji-Bandpy M, Goodarzian H. Exergoeconomic Optimization of Gas Turbine Power Plant Operating Parameters Using Genetic Algorithm: A Case Study. *J Thermal Science* 2011; 15: 43-54.
13. Kumar M, Guria C. The elitist non-dominated sorting genetic algorithm with inheritance (i-NSGA-II) and its jumping gene adaptations for multi-objective optimization. *Information Science* 2017; 382-383: 15-37.
14. Goldberg DE. Genetic algorithms in search, optimization, and machine learning. Reading, Mass, Harlow: Addison-Wesley. 1989.
15. Michalewicz Z. Genetic algorithms + data structures = evolution programs. 3rd ed. Berlin, New York: Springer-Verlag. 1996.
16. Janawitz J, Masso J, Christopher Childs. Heavy-Duty Gas Turbine Operating and Maintenance Consideration Ger 3620M. GE Power and Water, Atlanta, Georgia, February. 2015.
17. Ogbe PO, Anosike NB, Okonkwo UC. Exergoeconomic

Evaluation of Transcorp Power Plant Ughelli, International Research *Journal of Engineering and Technology* 2016; 3(11): 36-44.

18. Igbong DI, Fakorede DO. Exergoeconomic Analysis of 100 MW Unit GE Frame 9 Gas Turbine Plant at Ughelli, Nigeria, *International Journal of Engineering and Technology* 2014; 4(8): 463-468.

Date of Submission: 2018-12-14

Date of Acceptance: 2018-12-26